



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146DL0420

Registration Number
Registriernummer

| | |
|---|---|
| Field of Application <i>Anwendungsbereich</i> | products of gas supply <i>Produkte der Gasversorgung</i> |
| Owner of Certificate <i>Zertifikatinhaber</i> | Wiko Klebetechnik Sp. z o.o. ul. Ekonomiczna 8, PL-42-271 Czestochowa |
| Distributor <i>Vertreiber</i> | Wiko Klebetechnik Sp. z o.o. ul. Ekonomiczna 8, PL-42-271 Czestochowa |
| Product Category <i>Produktart</i> | Greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146) |
| Product description <i>Produktbezeichnung</i> | Anaerobic sealing material for metallic threaded joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2018 |
| Model <i>Modell</i> | 05K77UF |
| Test reports <i>Prüfberichte</i> | Type testing: 20-00560 from 24.11.2020 (EBI) Laboratory control test: 20-00560-KP05 from 07.02.2025 (EBI) |
| Test basis <i>Prüfgrundlagen</i> | DIN EN 751-1 (01.05.1997) |
| Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i> | 24.11.2030 / 25-0304-GNV |

70028-04-A-DE

04.09.2025 Koh A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

| Type | Technical Data | Remarks |
|------------|-------------------------|-----------------------------------|
| <i>Typ</i> | <i>Technische Daten</i> | <i>Bemerkungen</i> |
| 05K77UF | Class: H | for diameters > DN 10 up to DN 50 |

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

not allowed: for use in the gas installation according to DVGW-TRGI 2018

The logo for DVGW CERT, featuring a stylized leaf-like symbol above the text 'DVGW' and 'CERT' separated by a horizontal line.